SHALLCO
308 COMPONENTS DRIVE
SMITHFIELD, NC 27577 USA
919-934-3134 shallco@shallco.com

SERIES 26

MANUAL LOCK-OUT RELAY PART NUMBERING SYSTEM

LOCK-OUT RELAY PART NO. BUILD UP SEQUENCE

LIGHTED PANEL INFORMATION (WHEN REQUIRED)

BASE LOCK-OUT RELAY (L1) (L2)

76XXX XXXXXXXXXXX

VOLTAGE 5 OR 6 DIGITS | LED POSITION AND COLOR | MOLEX PLUG (IF REQ)



NO. OF DECKS
01 - 12

24VDC
48VDC
125VDC

WP



MOLEX PLUG

COIL SELECTION

STD COLORS
A = RED
B = AMBER
C = GREEN
D = BLUE
E = WHITE
X = NO LED

STANDARD PANEL

A : 24 VDC (10 - 40 VDC)

B : 24 VDC (18 - 50 VDC)

C: 48 VDC (24 - 70 VDC)

D: 125 VDC (30 - 140 VDC)
120 VAC (30 - 140 VAC)

E: 125 VDC (45 - 140 VDC)

F: 250 VDC (70 - 280 VDC)
240 VAC (70 - 280 VAC)

G: 125 VDC (90 - 140 VDC)

H: 250 VDC (180 - 280 VDC)

K: 125 VDC (30 - 140 VDC)



LIGHTED PANEL

AVAILABLE TRIP COILS

A : 24 VDC (10 - 40 VDC)

B : 24 VDC (18 - 50 VDC)

C: 48 VDC (24 - 70 VDC)

D: 125 VDC (30 - 140 VDC)

E: 125 VDC (45 - 140 VDC)

G: 125 VDC (90 - 140 VDC)

K: 125 VDC (30 - 140 VDC)



CONTROL CIRCUIT DIAGRAMS



STANDARD



LIGHTED ESCUTCHEON





EXAMPLES:

7605D
MANUAL LOCK-OUT RELAY
5 SECTIONS
STANDARD PANEL
COIL: 125 VDC/120VAC

7606E 125VDCAXC
MANUAL LOCK-OUT RELAY
6 SECTIONS
COIL & PANEL: 125 VDC
LED'S: RED (L1) GREEN (L2)

7602B 24VDCDXXWP
MANUAL LOCK-OUT RELAY
2 SECTIONS
COIL & PANEL: 24 VDC
LED'S: BLUE (L1)
WITH MOLEX PLUG CONNECTION

SHALLCO